| JOB NAME   |  |
|------------|--|
| ARCHITECT  |  |
| ENGINEER   |  |
| CONTRACTOR |  |
| LOCATION   |  |


# SUBMITTAL SHEET

Form Number GS0602

Effective Date 9/04



# SVE w/ PNEUMATIC CONTROLS CONSTANT VOLUME TO VARIABLE VOLUME RETROFIT TERMINAL UNIT



### Standard Features:

- Converts constant volume systems to variable air volume.
- Easy, low cost installation into rectangular duct. The installer simply cuts a rectangular hole in the side of the duct, cuts away the insulation (where present), slides the unit into the duct and screws the mounting plate to the side of the duct.
- LineaCross inlet sensor with center averaging.
- · Pressure independent operation.
- Tight close-off damper. Leakage is less than 2% at 6" W.G. Ps.
- Damper is constructed of 16 gage galvanized steel.
- Units equipped with a velocity controller that can be either direct acting or reverse acting, with the damper either normally open or normally closed.
- Pneumatic damper actuator is an integral part of the terminal unit.
- Gauge tees for CFM measurement and balancing.
- Gaskets under the mounting plate and at the end of the orifice plate seal the unit to the sides of the duct.

#### **Dimensions**

| Unit       | CFM Maximum |               | Available Duct Sizes               |                |
|------------|-------------|---------------|------------------------------------|----------------|
| Size       | Range *     | CFM **        | Width (W)                          | Height (H)     |
|            |             |               | 5, 6, 8, 10, 12                    | 5              |
| Α          | 0 to 200    | 100 to 200    | 6, 8, 10, 12                       | 6              |
|            |             |               | 8, 10, 12                          | 8              |
| В          | 0 to 300    | 150 to 300    | 6, 8, 10, 12, 14                   | 6              |
|            |             |               | 8, 10, 12, 14                      | 8              |
|            |             |               | 10, 12, 14                         | 10             |
| С          | 0 to 400    | 200 to 400    | 8, 10, 12, 14, 16                  | 6, 8           |
| Ľ          | 0 10 400    |               | 10, 12, 14, 16                     | 10             |
| D          | 0 to 700    | 350 to 700    | 10, 12, 14, 16, 18                 | 8, 10          |
| لـــّــا   | 0 10 7 00   |               | 12, 14, 16, 18                     | 12             |
| Е          | 0 to 1000   | 500 to 1000   | 14, 16, 18, 20, 22, 24             | 8, 10, 12      |
| F          | 0 to 1000   | 500 to 1000   | 18, 20, 22, 24, 26                 |                |
| <b>G</b> 0 | 0 to 1100   | 600 to 1100   | 12, 14, 16, 18, 20, 22             | 10, 12         |
|            | 0 10 1100   |               | 14, 16, 18, 20, 22                 | 14             |
| Н          | 0 to 1900   | 800 to 1900   | 18, 20, 22, 24, 26, 28, 30         | , ,            |
| J          | 0 to 2400   | 1000 to 2400  | 18, 20, 22, 24, 26, 28             | , ,            |
| K          | 0 to 3800   | 1350 to 3800  | 20, 22, 24, 26, 28, 30             | , ,            |
| L          | 0 to 5400   | 1800 to 5400  | 30, 32, 34, 36                     | , ,            |
| М          | 0 to 5400   | 1750 to 5400  | 22, 24, 26, 28, 30, 32, 34, 36     | , ,            |
| N          | 0 to 6700   | 2300 to 6700  | 24, 26, 28, 30, 32, 34, 36         | 18, 20, 24, 26 |
| Р          | 0 to 10000  | 4000 to 10000 | 30, 32, 34, 36, 38, 40, 42, 44, 46 | 20, 24, 26     |
| R          | 0 to 15000  | 5000 to 15000 | 40, 42, 44, 46, 48, 50, 52         | 20, 24, 26     |

#### Notes:

- (\*) CFM range from lowest minimum setting to highest maximum setting.
- (\*\*) Range of maximum CFM setting.
- Width (W) and Height (H) are in inches.

## Options:

☐ Thermostat