
JOB NAME	
ARCHITECT	
ENGINEER	
CONTRACTOR	
LOCATION	

	SUBMITTAL SHEET
Form Nu	mber TUIN00.3 Effective Date 3/25
	Replaces From TUIN00.2
	<i>KRUEGER</i>
	ANOLULN
	Eventiones in Air Distribution

## 1/2" Dual Density (Standard) Insulation Submittal



## **Physical Properties**

**Dual Density Fiberglass** Material

Thickness 1/2 inch R-Value 1.9 @ 75° F

1.5 lbs / ft3 with 4.0 lbs / ft3 Face Density 0.52 Btu / hr ft2 °F@ 75° F Thermal Conductance (C)

250°F / (121°C) Maximum Operating Temperature Maximum Air Velocity 3600 FPM Flame Spread Less than 25

**Smoke Density** Less than 50 None

Mold Growth and Humidity

**Edge Treatment** Sealant (NFPA 90A Approved)

## **Code Compliances**

UL 181 Air Erosion

UL 181 Mold Growth and Humidity **UL 723** Flame / Smoke Spread (25/50) Flame / Smoke Spread (25/50) NFPA 255

NFPA 90A & 90B **Appliances** 

Flame / Smoke Spread (25/50) ASTM E 84

**ASTM C 1071** Fiberglass Duct Liner CAN/ULC-S102 Flame Spread Rating



Warning: This product can expose you to chemicals including formaldehyde, which is known to the State of California to cause cancer. For more information go to www.P65Warnings.ca.gov.