

**KVPE/KVPP - VERTICAL STACK FAN COIL**  
 SUGGESTED RISER FLOOR OPENINGS MODEL "KVPE & KVPP" UNITS

USE THIS CHART TO DETERMINE LENGTH OF SLOT NEEDED, LENGTH IS MEASURED PARALLEL TO UNIT HEIGHT. SEE ILLUSTRATIONS TO THE RIGHT.

UNIT SIZE	PIPE DIAMETER	INSTALLATION METHOD			
		A	B	C	D
03-04	3/4 TO 1-1/2	11-11/16	18-9/16	4-5/8	8-11/16
	2 TO 3	13-1/16	20	6-1/16	10
	ADD PER INCH OVER 100	5/8	11/16	1/4	11/16
06-08	3/4 TO 1-1/2	11-3/4	18-7/16	5-1/2	8-11/16
	2 TO 3	12-15/16	19-7/8	6	10
	ADD PER INCH OVER 100	9/16	11/16	1/4	11/16
10-12	3/4 TO 1-1/2	11-5/16	18-1/4	4-5/16	8-11/16
	2 TO 3	12-11/16	19-11/16	5-13/16	10
	ADD PER INCH OVER 100	1/2	9/16	1/4	11/16

USE THIS CHART TO DETERMINE WIDTH OF SLOT NEEDED, WIDTH IS MEASURED PERPENDICULAR TO UNIT HEIGHT. SEE ILLUSTRATIONS TO THE RIGHT.

PIPE DIAMETER		SLOT WIDTH			
		A	B	C	D
3/4"	2 PIPE	2-3/4"	N/A	8-3/4"	USE C
	4 PIPE	N/A	2-3/4"	16"	USE C
1"	2 PIPE	3"	N/A	9"	USE C
	4 PIPE	N/A	3"	16-1/4"	USE C
1-1/4"	2 PIPE	3-1/4"	N/A	9-1/4"	USE C
	4 PIPE	N/A	3-1/4"	16-1/2"	USE C
1-1/2"	2 PIPE	3-1/2"	N/A	9-1/2"	USE C
	4 PIPE	N/A	3-1/2"	16-3/4"	USE C
2"	2 PIPE	4"	N/A	10"	USE C
	4 PIPE	N/A	4"	17-1/4"	USE C
2-1/2"	2 PIPE	4-1/2"	N/A	10-1/2"	USE C
	4 PIPE	N/A	4-1/2"	17-3/4"	USE C
3"	2 PIPE	5"	N/A	11"	USE C
	4 PIPE	N/A	5"	18-1/4"	USE C

NOTE:  
 SOME UNITS MAY HAVE DIFFERENT LENGTH AND DIAMETERS OF PIPE. ALWAYS USE THE LONGEST AND/OR LARGEST DIAMETER WHEN DETERMINING SLOT LENGTHS AND WIDTHS.

