


RVE SERIES With Pneumatic Controls

JOB NAME	
ENGINEER	
CONTRACTOR	
TAG	

SUBMITTAL SHEET



INLET	А	В	O	D	Н	L	MAXCFM	MIN CFM	
SIZE							[L/s]	[L/s]	
4	3 9/16 (90)	4 1/16 (103)	6 (153)	3 7/8 (98)	12 (305)	18 (457)	230 [109]	40 [19]	
5	3 9/16 (90)	3 9/16 (90)	6 (153)	4 7/8 (124)	12 (305)	18 (457)	360 [170]	62 [29]	
6	3 9/16 (90)	3 1/16 (78)	6 (153)	5 7/8 (149)	12 (305)	16 (406)	515 [243]	89 [42]	
7	4 1/16 (103)	2 9/16 (65)	6 (153)	6 7/8 (175)	12 (305)	16 (406)	700 [330]	121 [57]	
8	4 9/16 (116)	2 1/16 (52)	6 (153)	7 7/8 (200)	12 (305)	16 (406)	920 [434]	159 [75]	
9	5 1/16 (129)	1 9/16 (40)	6 (153)	8 7/8 (225)	12 (305)	20 (508)	1160 [547]	201 [94]	
10	5 9/16 (141)	1 1/16 (27)	6 (153)	9 7/8 (251)	12 (305)	20 (508)	1430 [675]	248 [117]	
12	6 9/16 (167)	1/16 (2)	6 (153)	11 7/8 (302)	12 (305)	20 (508)	2060 [972]	357 [168]	
14	7 9/16 (192)	1/16 (2)	7 (178)	13 7/8 (352)	14 (356)	24 (610)	2800 [1321]	486 [229]	
16	8 9/16 (217)	1/16 (2)	8 (203)	15 7/8 (403)	16 (406)	24 (610)	3660 [1727]	634 [299]	
NOTE Disconsisse Ass Chaves In Inches (1999)									

NOTE: Dimensions Are Shown In Inches (mm)

STANDARD FEATURES:

- 22 GA. Steel Construction
- Linear Averaging Airflow Sensor
- Inlet Sizes 4 and 5 Require an Inlet Adapter
- "D" Dimension is Diameter of Inlet
- Variety of Pneumatic Control Packages

OPTIONAL FEATURES:

- ☐ 20 GA. Steel Casing Construction
- ☐ 304 Stainless Steel Construction
- ☐ 316 Stainless Steel Construction
- ☐ Four Quadrant Center Averaging Airflow Sensor
- ☐ Transformer

Revision Date: 05/10 Form: GS0501.2 Replaces: GS0501.1