







JOB NAME \_\_\_\_\_  
 ARCHITECT \_\_\_\_\_  
 ENGINEER \_\_\_\_\_  
 CONTRACTOR \_\_\_\_\_  
 LOCATION \_\_\_\_\_

**SUBMITTAL SHEET**  
 Form Number DS0355 Effective Date 8/00  
 NEW



**5000 / 5000HF SERIES**  
**GENERAL INSTALLATION INSTRUCTIONS**

 <p><b>SURFACE MOUNT FRAME 22</b>        OPENING SIZE TYPICAL OF BOTH 5000 &amp; 5000HF</p>	 <p><b>'TEE' BAR LAY IN FRAME 23</b>        OPENING SIZE TYPICAL OF BOTH 5000 &amp; 5000HF</p>
<p><b>FR22-1</b> SIZE OPENING AS SHOWN ABOVE</p>	<p><b>FR23-1</b> LAYOUT 'TEE' BAR GRID AS SHOWN</p>
 <p><b>FR22-2</b> LOCATE <b>5000/5000HF</b> BACK PAN ASSEMBLY AGAINST CEILING - BEND OUT HANGER TABS AT EACH CORNER &amp; ATTACH TO STRUCTURAL SUPPORT ABOVE</p>	 <p><b>FR23-2</b> LOCATE <b>5000/5000HF</b> BACK PAN ASSEMBLY IN 'TEE' BAR GRID - BEND OUT HANGER TABS AT EACH CORNER &amp; ATTACH TO STRUCTURAL SUPPORT ABOVE</p>
 <p><b>FR22-3</b> ATTACH <b>5000/5000HF</b> UNIT FACE TO BACK PAN SAFETY CABLES - INSTALL FACE WITH CAPTIVE QUARTER TURN FASTENERS</p>	 <p><b>FR23-3</b> ATTACH <b>5000/5000HF</b> UNIT FACE TO BACK PAN SAFETY CABLES - INSTALL FACE WITH CAPTIVE QUARTER TURN FASTENERS</p>
<p>Product Information is Subject to Change Without Notice</p>	