0



# R580 Series | Round Single Deflection

# R580, R580RD, R580RR Suggested Specification & Configuration

## 1. SERIES: (XXXXXX)

R580 - Aluminum, Round Single Deflection,

**Concealed Mount** 

R580RD - Aluminum, Round Single Deflection,

Round Duct Adaptor

R580RR - Aluminum, Round Single Deflection,

Round Duct Reducer

## 2. SIZE: (XX) \*

06 - 6" Unit Size

08 - 8" Unit Size

10 - 10" Unit Size

12 - 12" Unit Size

14 - 14" Unit Size

16 - 16" Unit Size

18 - 18" Unit Size

20 - 20" Unit Size

22 - 22" Unit Size

24 - 24" Unit Size

## 3. FINISH: (XX)

01 - Mill

36 - Black

44 - British White

50 - Bright White

61 - Gray Prime

70 - Silver Metallic

99 - Custom Color

#### R580

The single deflection round supply grille shall be a Krueger model R580. This grille must have individually adjustable blades on 1" centers with friction pivots made of extruded aluminum with an airfoil shape and have a maximum thickness of .2275" and a minimum thickness of no less than .0625". The flange of the R580 shall be made of aluminum and have a minimum thickness of .072". A foam gasket on the reverse side of the flange shall be provided by the manufacturer. The single deflection round supply grille shall have a concealed mounting system that includes a separate duct mounting ring. Screw holes on the face of the unit are not acceptable.

### **R580RD**

The single deflection round supply grille shall be a Krueger model R580RD. This grille must have individually adjustable blades on 1" centers with friction pivots made of extruded aluminum with an airfoil shape and have a maximum thickness of .2275" and a minimum thickness of no less than .0625". The flange of the R580RD shall be made of aluminum and have a minimum thickness of .072". The single deflection round supply grille shall slide cleanly over the end of exposed duct work and be secured with screws provided by the manufacturer. The screws shall mount to the side of the grille. Screw holes on the face of the unit are not acceptable.

## **R580RR**

The single deflection round supply grille shall be a Krueger model R580RR. This grille must have individually adjustable blades on 1" centers with friction pivots made of extruded aluminum with an airfoil shape and have a maximum thickness of .2275" and a minimum thickness of no less than .0625". The flange of the R580RR shall be made of aluminum and have a minimum thickness of .072". The single deflection round supply grille shall slide cleanly into end of exposed duct work and be secured with screws provided by the manufacturer. The screws shall mount to the side of the grille. Screw holes on the face of the unit are not acceptable.

## **PERFORMANCE**

The manufacturer shall provide published performance data for the grille. The grille shall be tested in accordance to the data standards at the time of product introduction or ANSI/ASHRAE Standard 70.

## **FINISH**

The paint finish shall be #70 Silver Metallic and be a P-Series Powder Coating finish, baked at  $400^{\circ}F$  for 7 minutes. The paint thickness shall be 1.8-2.2 mils, pencil hardness per ASTM D3363 of H – 2H, crosshatch adhesion per ASTM D3359 of 4B, impact per ASTM D2794 of direct and reverse impact range of 40 to 160 in/lb depending on formulation, salt spray per ASTM B117 of 1000 hours, humidity per ASTM D2247 of 1000 hours and water soak per ASTM D8702 of 500 hours.

<sup>\*</sup> Unit and duct sizes are not the same for model R580RD.