




KBH, KBV - HORIZONTAL & VERTITCAL BLOWER COIL STANDARD MIXING BOX

JOB NAME
ENGINEER
CONTRACTOR
TAG


SUBMITTAL SHEET








TOP VIEWS







BOT/REAR INLET

SIDE VIEWS

3 [76] -	- A -
A/F H 1 [25]	- A - - 3 [76]
+	D

TOP/BOT INLET

SIZE	Н	W	Α	В	С	D
08	21	30	9	18	6	18
	[533]	[762]	[229]	[457]	[152]	[457]
12	21	36	9	24	6	18
	[533]	[914]	[229]	[610]	[152]	[457]
16	21	44	9	30	7	18
	[533]	[1118]	[229]	[762]	[178]	[457]
20	21	50	12	36	7	21
	[533]	[1270]	[305]	[914]	[178]	[533]
30	30	59	12	45	7	21
	[762]	[1499]	[305]	[1143]	[178]	[533]
40	30	68	15	48	10	24
	[762]	[1727]	[381]	[1219]	[254]	[610]

NOTES:

- 1. ALL DIMENSIONS ARE INCHES [MM]
- 2. ALL DIMENSIONS ARE ±1/4" [6]
- 3. METRIC VALUES ARE SOFT CONVERSION
- DAMPER DRIVE RODS ARE INTERNAL; LOCATED ON BOTH SIDES OF UNIT
- MIXING BOX INCLUDES SPACE FOR STANDARD FILTER RACK; SEE SUBMITTAL BCS07-BR01; BASE RAILS MUST BE USED WITH MIXING BOX

Revision Date: 11/14 Form: BCS07-MB01 Replaces: NEW