



KSB, KSL - VERTICAL DOWNSIZED BLOWER COIL COIL CONNECTION LOCATION - 4 PIPE INTERNAL WATER COIL, RE-HEAT

JOB NAME	
ENGINEER	
CONTRACTOR	
TAG	

SUBMITTAL SHEET

FIG. 2 4/1, AND 4/2 ROW (HW COIL IN RE-HEAT POSITION)





RIGHT HAND UNIT

	INTERNAL COIL													
	4/1 ROW COILS						4/2 ROW COILS							
SIZE	4 ROW			1 ROW			4 ROW			2 ROW				
	COIL CONNECTION	Α	В	COIL CONNECTION	С	D	COIL CONNECTION	Α	В	COIL CONNECTION	С	D		
08	7/8 [23]	7-1/4 [184]	21-3/4 [552]	5/8 [16]	8 [203]	20-5/8 [524]	7/8 [23]	7-1/4 [184]	21-3/4 [552]	5/8 [16]	8 [203]	21-3/4 [552]		
12			26-1/4 [667]			22-7/8 [581]			26-1/4 [667]			26-1/8 [664]		
16			28-1/4 [716]			26-1/8 [664]			28-1/4 [716]			28-1/4 [718]		
20			33-5/8 [854]			33-3/4 [857]			33-5/8 [854]			34-3/4 [883]		
25	1-1/8 [29]	7-1/16 [179]	30-1/2 [775]		[746] 8-1/8 33-5/8	29-3/8 [746]	1-1/8	7-1/16 [179]	30-1/2 [775]	7/8	8-1/4 [210]			
30			34-7/8 [886]	7/8 [23]					34-7/8 [886]			35-1/4 [895]		

NOTES:

- ALL DIMENSIONS ARE INCHES [MM]
- ALL DIMENSIONS ARE ±1/2" [13]
 METRIC VALUES ARE SOFT CONVERSION
- 4. STANDARD GALVANIZED DRAIN PAN HAS 1-18" ODM COPPER CONNECTION; OPTIONAL STEEL DRAIN PAN HAS 1" GALVANIZED SCH. 40 THREADED STEEL CONNECTION
- 4-PIPE UNITS WITH INTERNAL COILS HAVE COOLING AND HEATING CONNECTIONS ON OPPOSITE SIDES OF UNIT
- ALL INTERNAL HEATING COILS ARE IN THE RE-HEAT POSITION
- DIMENSIONS ARE BASED ON UNIT CABINET ONLY, AND DO NOT INCLUDES FILTER RACK OR BASE RAIL

12/14 BCS20-SWC02 NEW Revision Date: Form: Replaces: