


JOB NAME	
ENGINEER	
CONTRACTOR	1
TAG	

KBM - AIR HANDLER, MODULAR COIL CONNECTION LOCATION - 8 ROW WATER COIL IN COOLING WITH STEAM RE-HEAT COIL

SUBMITTAL SHEET



COIL 2										
	1 ROW				2 ROW					
SIZE	А	В	С	D	Е	А	В	С	D	Е
02	16-1/2	4-1/4	4-3/4	11-3/4	16-3/4	16-1/4	4-1/4	5	11-3/4	16-3/4
02	[420]	[108]	[121]	[298]	[425]	[413]	[108]	[127]	[298]	[425]
03	16-1/2	4-1/4	5	11-3/4	16-3/4	16-1/4	4-1/4	5	11-3/4	16-3/4
00	[420]	[108]	[127]	[298]	[425]	[413]	[108]	[127]	[298]	[425]
04	16-1/2	4-3/4	5-1/4	11-3/4	17	16-1/4	4-3/4	5-1/4	11-3/4	17
04	[420]	[121]	[133]	[298]	[432]	[413]	[121]	[133]	[298]	[432]
06	16-1/2	4-3/4	5-1/4	15-1/2	24-1/2	16-1/4	4-3/4	5-1/2	15-1/2	24-1/2
00	[420]	[121]	[133]	[394]	[622]	[413]	[121]	[140]	[394]	[622]
08	16-1/2	4-3/4	6-3/4	18	29-3/4	16-1/4	4-3/4	5-3/4	18	29-3/4
00	[420]	[121]	[171]	[457]	[756]	[413]	[121]	[146]	[457]	[756]
10	16-1/2	4-3/4	6-1/2	18	29-1/2	16-1/4	4-3/4	6-1/2	18	29-1/2
10	[420]	[121]	[165]	[457]	[749]	[413]	[121]	[165]	[457]	[749]
12	16-1/2	5-3/4	7-1/4	20-1/2	35-1/4	16-1/4	5-3/4	7-1/4	20-1/2	35-1/4
12	[420]	[147]	[185]	[521]	[895]	[413]	[147]	[184]	[521]	[895]
14	16-1/2	5-3/4	7-1/4	21-3/4	37-3/4	16-1/4	5-3/4	7-1/4	21-3/4	37-3/4
1-7	[420]	[147]	[185]	[552]	[959]	[413]	[147]	[184]	[552]	[959]
17	16-1/2	6	7-1/2	21-3/4	38	16-1/4	6	7-1/2	21-3/4	38
	[420]	[153]	[191]	[552]	[965]	[413]	[153]	[191]	[552]	[965]

NOTES:

ALL DIMENSIONS ARE INCHES [MM] 1.

2.

3. 4.

ALL DIMENSIONS ARE inches [mm] ALL DIMENSIONS ARE ±1/8" [3] METRIC VALUES ARE SOFT CONVERSION SEE SELECTION PROGRAM FOR CONNECTION SIZES CHILLED WATER COILS ARE ONLY AVAILABLE IN 4, 6, OR 8 ROWS STEAM COILS ARE NON-DISTRIBUTING AND ARE ONLY AVAILABLE IN 1 & 2 ROWS 5. 6. 7.

MODULE MCM CAN HAVE UP TO A TOTAL OF 10 ROWS OF COIL

Revision Date: 12/14 Form: AHMS05-WC31	Replaces: NEW
--	---------------