



SIZE	A	B	C	D	E	F
20	40 [1016]	20 [508]	6 [152]	37 [940]	27-1/2 [699]	6-1/4 [159]
25	46 [1168]	26 [660]	6 [152]	43 [1092]	35-1/2 [902]	5-1/4 [133]
30	50 [1270]	30 [762]	6 [152]	47 [1194]	39-1/2 [1003]	5-1/4 [133]
40	60 [1524]	40 [1016]	6 [152]	57 [1448]	47-1/2 [1207]	6-1/4 [159]
50	70 [1778]	50 [1270]	6 [152]	67 [1702]	59-1/2 [1511]	5-1/4 [133]
60	80 [2032]	60 [1524]	6 [152]	77 [1956]	67-1/2 [1715]	6-1/4 [159]

NOTES:

- ALL DIMENSIONS ARE INCHES [MM]
- ALL DIMENSIONS ARE $\pm 1/4"$ [6]
- METRIC VALUES ARE SOFT CONVERSION
- LEFT HAND UNIT SHOWN, RIGHT HAND UNIT OPPOSITE
- ELECTRICAL ENCLOSURE SIZE AND LOCATION MAY VARY WITH OPTIONAL FEATURES
- PROVIDE SUFFICIENT CLEARANCE TO ACCESS ELECTRICAL CONTROLS.
- COMPLY WITH APPLICABLE CODES AND ORDINANCES
- DRAIN PIPING SHOULD BE ROUTED THROUGH CASING OPENING INDICATED TO PROVIDE PROPER DRAIN SLOPE
- LOUVERED BOTTOM PANEL IS HINGED AND REMOVABLE FOR ACCESS TO FILTER AND FAN ASSEMBLY
- FIXED BOTTOM PANEL IS REMOVABLE FOR ACCESS TO OPTIONAL ELECTRICAL ENCLOSURE, COIL, AND DRAIN PAN
- INTERNAL INSULATION OF FIELD PIPING MAY BE REQUIRED
- FIELD PIPING CASING PENETRATIONS MUST BE CUT IN THE FIELD TO MATCH INDIVIDUAL JOB REQUIREMENTS

Revision Date:

04/15

Form:

FCS01-KHFE07

Replaces:

NEW