


JOB NAME
ENGINEER
CONTRACTOR
TAG

8-1/2 [216] REQUIRED FOR FILTER REMOVAL

SUBMITTAL SHEET



SIZE	Α	С	D	Е	F
20	20	21	22	19	30
	[508]	[533]	[559]	[483]	[762]
25	26	27	28	25	36
	[660]	[686]	[711]	[635]	[914]
30	30	31	32	29	40
	[762]	[787]	[813]	[737]	[1016]
40	40	41	42	39	50
	[1016]	[1041]	[1067]	[991]	[1270]
50	50	51	52	49	60
	[1270]	[1295]	[1321]	[1245]	[1524]
60	60	61	62	59	70
	[1524]	[1549]	[1575]	[1499]	[1778]

OPTIONAL AUX. DRAIN_ OUTLET, SEE NOTE 12 DRAIN PAN OUTLET SEE NOTE 1 9 [229] REQUIRED FOR HINGED BOTTOM— ENCLOSURE COVER

ELECTRICAL K.O. SEE NOTE 5

SIDE VIEW

NOTES

- 1. ALL DIMENSIONS ARE INCHES [MM]
- 2. ALL DIMENSIONS ARE ±1/4" [6]
- 3. METRIC VALUES ARE SOFT CONVERSION
- 4. LEFT HAND UNIT SHOWN, RIGHT HAND UNIT OPPOSITE
- 5. STANDARD CONTROL ENCLOSURE IS MOUNTED ON UNIT SIDE OPPOSITE COOLING COIL CONNECTIONS

FRONT VIEW

- 6. UNIT CASING INCLUDES (2) KNOCKOUTS ON EACH SIDE
- 7. PROVIDE SUFFICIENT CLEARANCE TO ACCESS ELECTRICAL CONTROLS AND COMPLY WITH APPLICABLE CODES AND ORDINANCES
- 8. OPTIONAL BOTTOM CONTROL ENCLOSURE WITH HINGED COVER REPLACES STANDARD SIDE MOUNTED ENCLOSURE
- 9. INCLUDES (2) ADDITIONAL KNOCKOUTS ON BOTTOM OF UNIT, ON LEFT SIDE
- 10. STANDARD EXTERNALLY FOAM COATED GALVANIZED STEEL DRAIN PAN HAS 7/8" ODM COPPER OUTLET
- 11. STAINLESS STEEL DRAIN PAN HAS 3/4" MPT GALVANIZED STEEL OUTLET.
- 12. AUX. DRAIN OUTLET IS 5/8" ODM COPPER OR 3/8" MPT GALVANIZED STEEL RESPECTIVELY
- 3. SEE COIL CONNECTION DRAWING FOR COIL CONNECTION SIZES AND LOCATIONS

Revision Date: 04/15 Form: FCS01-KHFP01-02 Replaces: FCS01-KHFP01-01