
## **EXAMPLE OF CONTAL FAN COIL** 2 & 4 PIPE FAN COIL UNIT WITH 6" ROUND SIDE O.A. INLET

JOB NAME ENGINEER CONTRACTOR TAG

SUBMITTAL SHEET



SIZE	A	С	D	E	F
20	20	21	22	19	30
20	[508]	[533]	[559]	[483]	[762]
25	26	27	28	25	36
20	[660]	[686]	[711]	[635]	[914]
30	30	31	32	29	40
50	[762]	[787]	[813]	[737]	[1016]
40	40	41	42	39	50
40	[1016]	[1041]	[1067]	[991]	[1270]
50	50	51	52	49	60
50	[1270]	[1295]	[1321]	[1245]	[1524]
60	60	61	62	59	70
00	[1524]	[1549]	[1575]	[1499]	[1778]

NOTES:

1. ALL DIMENSIONS ARE INCHES [MM]

2. ALL DIMENSIONS ARE ±1/4" [6]

3. METRIC VALUES ARE SOFT CONVERSION

4. LEFT HAND UNIT SHOWN, RIGHT HAND UNIT OPPOSITE

5. STANDARD CONTROL ENCLOSURE IS MOUNTED ON UNIT SIDE OPPOSITE COOLING COIL CONNECTIONS

6. UNIT CASING INCLUDES (2) KNOCKOUTS ON EACH SIDE

7. PROVIDE SUFFICIENT CLEARANCE TO ACCESS ELECTRICAL CONTROLS AND COMPLY WITH APPLICABLE CODES AND ORDINANCES

8. OPTIONAL BOTTOM CONTROL ENCLOSURE WITH HINGED COVER REPLACES STANDARD SIDE MOUNTED ENCLOSURE

9. INCLUDES (2) ADDITIONAL KNOCKOUTS ON BOTTOM OF UNIT, ON LEFT SIDE

10. STANDARD EXTERNALLY FOAM COATED GALVANIZED STEEL DRAIN PAN HAS 7/8" ODM COPPER OUTLET

11. STAINLESS STEEL DRAIN PAN HAS 3/4" MPT GALVANIZED STEEL OUTLET

12. AUX. DRAIN OUTLET IS 5/8" ODM COPPER OR 3/8" MPT GALVANIZED STEEL RESPECTIVELY

13. SEE COIL CONNECTION DRAWINGS FOR COIL CONNECTION SIZES AND LOCATIONS

14. OUTSIDE AIR INLET IS UNFILTERED, AND MAY BE LOCATED ON LEFT OR RIGHT SIDE OF UNIT

			Replaces:	FCS01-KHFP07-01
--	--	--	-----------	-----------------

Product Information is Subject to Change Without Notice