


JOB NAME	
ENGINEER	
CONTRACTOR	
TAG	

## SUBMITTAL SHEET



DIMENSIONS - IN [MM]								
UNIT SIZE	А	В	SINGLE/DOUBLE		Е	F		
			С	D		Г		
03 & 04	18	16-1/2	16	8	6	6.81		
	[457]	[419]	[406]	[203]	[152]	[173]		
06 & 08	20	18-1/2	18	12	6	6.47		
	[508]	[470]	[457]	[305]	[152]	[164]		
10 & 12	24	22-1/2	22	14	8	4.9		
	[610]	[572]	[559]	[356]	[203]	[124]		

## NOTES:

- ALL DIMENSIONS ARE INCHES [MM]. METRIC VALUES ARES OFT CONVERSION.
- ALL DIMENSIONS ARE ±1/4 [6MM].
- 3. TILE RING INSTALLED ON FRONT OF UNIT (SHOWN) MAY MOVE TO LEFT OR RIGHT SIDE OF UNIT IN FIELD.
- TILE RING OMITTED ON UNITS WITH "ADA" CONTROL MOUNTING LOCATION.
- 5. WIRING ELECTRICAL ENTRY POINT TO CONTROL ENCLOSURE IS FURNISHED/INSTALLED BY OTHERS IN FIELD.
- RISERS AVAILABLE FROM 3/4" [19MM] TO 3" [76MM] DIAMETER WITH 1/2" [13MM] THICK INSULATION RISERS ALSO AVAILABLE 3/4" [19MM] TO 2-1/2" [64MM] DIAMETER WITH 3/4" [19MM] THICK INSULATIONS.
- RISER LENGTH IS 120" [3048MM] MAX, 100" [2540MM] MIN.
- BACK RISER LOCATION SHOWN, SEE ARRANGEMENT DRAWINGS FOR AVAILABLE UNIT CONFIGURATIONS.
- FACTORY MOUNTED RISERS SHOWN, SEE DRAWING "FCS05-KVPE\_KVPP\_KVPS\_01" FOR SHIPPED LOOSE RISER DETAILS.

Revision Date: 04/15 FCS05-KVPH03 NEW Form Replaces: